

## **Fuseholders**

## For 3AG Fuses





## Low Profile Snap Mount Type





APPROVALS: Recognized under the Components Program of Underwriters Laboratories and Certified by CSA.

#### **SPECIFICATIONS:**

Electrical: 348 Series: Rated at 15 amps for any voltage up to 250 volts.

344 Series: Rated at 15 amps at lamp voltage shown below.

Dielectric Strength: 1500 volts minimum.

When designing indicating type fuseholders into a circuit, consideration should be given to the resistance of fractional amperage fuses and the parallel resistance of the indicator lamp and its resistor.

Mounting: Panel thickness range: .031" through .125".

Molded Parts: Black thermoplastic body (UL 94V0). Thermoplastic

bezel, cap and lens (UL94V2). See tables below for colors.


Terminals: Brass. Tin-plated. **Ambient Temperature:** 


Non-indicating: -40°C to +85°C.

Indicating: -40°C to +60°C.

Fuse Installation: Insert a fuse into the cap and push the assembly into the body until it latches. Press in and down to unlatch for removal.

\* Please refer to Fuseology section for information on proper fuseholder de-rating.





### **ORDERING INFORMATION:**

Six-Digit Catalog Numbers Consist of:							
Series Number	Terminal Style	Bezel Color	Cap Color				
	_	_	<u> </u>				
348 for 3AG Fuses	6 for <sup>3</sup> /16" wide NEMA Q.C. Terminal 8 for <sup>1</sup> /4" wide	7 for Black	1 for Red 7 for Black				


Example: **3 4 8** 6 1


# Blown-Fuse Indicating Snap Mount Type





APPROVALS AND SPECIFICATIONS: See above.





## **ORDERING INFORMATION:**

Catalog Number						
³/16" Q.C. Terminals	¹/₄" Q.C. Terminals	Lamp Type	Lamp Voltage	Lamp Current	Resistor	Lens Color
<b>344</b> 601	<b>344</b> 801	Incandescent	6	40 ma	No	Amber
<b>344</b> 602	<b>344</b> 802	Incandescent	14	80 ma	No	Amber
<b>344</b> 603	<b>344</b> 803	Incandescent	28	40 ma	No	Amber
<b>344</b> 604	<b>344</b> 804	Neon	120	1.2 ma	Yes	Clear
<b>344</b> 605	<b>344</b> 805	Neon	240	.3 ma	Yes	Clear