# TRIO-UPS/1AC/24DC/5

# Uninterruptible power supply with integrated power supply unit

# **INTERFACE**

Data sheet 104103 en 00

© PHOENIX CONTACT - 2009-09-01



# 1 Description

The TRIO-UPS/1AC/24DC/5 provides an uninterruptible 24 V DC voltage at a maximum load current of up to 5 A in both an error-free AC power supply network and in the event of power failure.

It is designed specifically for supplying industrial PCs (IPC).

The power supply unit and the electronic switch-over unit are housed in the same housing.

In the event of supply voltage failure, buffer mode is activated without interruption. In this operating mode, the output voltage is directly dependent on the battery voltage. In the event of a voltage dip, the IPC continues operating without interruption, thus increasing system availability. Uncontrolled shutdown is avoided.

The TRIO-UPS/1AC/24DC/5 can be parameterized using a service PC and the UPS-CONF configuration and management software via an IFS-USB-PROG-ADAPTER.

For convenient parameter transfer between various TRIO-UPS devices, the IFS-CONFSTICK configuration stick is available as an option.

#### **Features**

- Space-saving
  The TRIO-UPS combines a power supply unit and electronic switch-over unit in the same housing
- Flexible

Rechargeable battery module with 1.3, 3.4, 7.2 or 12 Ah

- Autonomous
   In the event of AC mains failure, the industrial PC continues operating without interruption
- Time-saving
   When the supply voltage is reapplied, the industrial PC starts automatically
- Parameterizable
   Can be parameterized with the PC or configuration stick



#### **DANGER**

Never carry out work when voltage is present.

The device contains dangerous live elements and high levels of stored energy.

Depending on the ambient temperature and load, the housing can become very hot.



Make sure you always use the latest documentation.

It can be downloaded at www.phoenixcontact.net/download.



This data sheet is valid for all products listed under "Ordering data" on page 3.



# Table of contents

2

1	Desc	ription	1
2	Table	e of contents	2
3	3 Ordering data		3
4	Techi 4.1	nical data	
	4.2	Battery management	
	4.3	Signaling and switching outputs	
	4.4 4.5	Ambient conditionsStandards/approvals	
5	_	y regulations	
		ection, operating, and indication elements	
6	6.1	Connection terminal blocks	
	6.2	Block diagram	
	6.3	Input	
	6.4	Output	
	6.5	LED indicators	
7	Instal	lation	11
	7.1	Narrow mounting position	11
	7.2	Flat mounting position	11
8	Rech	argeable battery module	12
9	Meth	od of operation	13
	9.1	Output voltage	13
	9.2	Remote shutdown	13
	9.3	Buffer time setting	
	9.4	PC mode	
	9.5 9.6	PC idle time	
10		aces	
10	10.1	ConfigPort	_
	10.1	IFS-USB-PROG-ADAPTER	
	10.2	IFS-CONFSTICK	
11	HPS.	CONE configuration and management software	16

# 3 Ordering data

# **UPS** system

Description	Туре	Order No.	Pcs./Pkt.
Uninterruptible power supply with integrated power supply unit	TRIO-UPS/1AC/24DC/5	2866611	1



The TRIO-UPS/1AC/24DC/5 is supplied without a rechargeable battery module. The rechargeable battery module must be ordered separately (see accessories).

# Accessories

Description	Туре	Order No.	Pcs./Pkt.
Rechargeable battery module, 24 V DC, 1.3 Ah	MINI-BAT/24DC/1.3AH	2866417	1
Rechargeable battery module, 24 V DC, 3.4 Ah	QUINT-BAT/24DC/3.4AH	2866349	1
Rechargeable battery module, 24 V DC, 7.2 Ah	QUINT-BAT/24DC/7.2AH	2866352	1
Rechargeable battery module, 24 V DC, 12 Ah	QUINT-BAT/24DC/12AH	2866365	1
Configuration and management software	UPS-CONF	2320403	1
USB data link cable between the UPS and IPC	IFS-USB-PROG-ADAPTER	2811271	1
Configuration stick for parameter transfer between various TRIO-UPS/1AC/24DC/5 devices	IFS-CONFSTICK	2986122	1

# 4 Technical data

### 4.1 I/O data

Input data	
Nominal input voltage (wide-range input)	100 240 V AC
Input voltage range (nominal load)	85 264 V AC (< 90 V AC derating: 2.5%/V) 100 350 V DC (UL508: 100 250 V)
Frequency	45 65 Hz
Approximate current consumption (mains operation and battery charging/maximum)	
At 230 V AC At 120 V AC	0.95 A/1.1 A 1.7 A/1.8 A
Inrush current limiting / I²t at 25°C	typical $< 44 \text{ A} / < 1.3 \text{ A}^2 \text{s}$
Switch-on time after applying the mains voltage	
At 230 V AC At 120 V AC	150 ms 200 ms
Transient surge protection	Varistor
Internal input fuse	T 6.3 A
Recommended backup fuse	
Circuit breaker	6 A/10 A/16 A (B characteristic)
Discharge current to PE	0.8 mA
Output data	
Rise time	< 100 ms
Residual ripple	< 10 mV <sub>PP</sub>
Switching peaks	< 25 mV <sub>PP</sub>
Parallel connection to increase the buffer time	Yes, 2
Surge protection against internal surge voltages	Yes, < 35 V DC
Maximum resistance to return supply	35 V DC

Output data in mains operation (AC input voltage present)		
Nominal output voltage U <sub>N</sub>	24 V DC	
Output voltage (adjustable)	22.5 29.5 V DC	
Nominal output current, > 24 V DC constant capacity (-25°C to +70°C)	5 A	
Derating (above 55°C)	2.5%/K	
Current limit	6 A, approximately	
Connection of capacitive loads	Yes, unlimited	
Control deviation	< 1% (static load change 10 90%)	
Approximate efficiency (mains operation and battery charging)		
At 230 V AC At 120 V AC	88% 86%	
Approximate power dissipation (mains operation and battery charging)		
At 230 V AC At 120 V AC	16 W 20 W	

Output data in battery operation (AC input voltage not present)		
Nominal output voltage U <sub>N</sub>	24 V DC	
Output voltage (U <sub>OUT</sub> = U <sub>BAT</sub> - 0.5 V)	27.9 19.2 V DC - 0.5 V	
Nominal output current (-25°C to +70°C)	5 A	
Derating (above 55°C)	2.5%/K	
Current limit	6 A, approximately	
Connection of capacitive loads	Yes, 3300 μF	
Efficiency	> 86%	
Power dissipation		
Maximum no load Maximum nominal load	2 W 4 W	
Maximum buffer time (adjustable per minutes)	0.5; 1; 2; 3; 5; 10; 15; 20; PC mode	
Overload fuse (electronic)	Yes	
Remote shutdown	Yes	

# 4.2 Battery management

Battery management	
Charging characteristic curve	I/U
Charging current <sup>1</sup> (preset/minimum/maximum)	1.0 A/0.2 A/1.5 A
End-of-charge voltage 1 (preset/minimum/maximum)	27,6 V DC / 25 V DC / 30 V DC
Temperature compensation <sup>1</sup> (preset/minimum/maximum)	42 mV/K / 0 mV/K / 200 mV/K
Battery presence check/time interval	60 s
Battery quality check <sup>1</sup> (preset/minimum/maximum)	12 h/4 h/200 h
Protection against total discharge <sup>1</sup> (preset/minimum/maximum)	19.2 V DC / 18 V DC / 21 V DC
"Battery almost flat" alarm signaling threshold <sup>1</sup> (preset/minimum/maximum)	20.4 V DC / 18 V DC / 30 V DC

<sup>&</sup>lt;sup>1</sup> Can be adjusted via UPS-CONF software

# 4.3 Signaling and switching outputs

Status indicators	
Mains voltage OK (Power in OK)	Green LED, static ON
Alarm	
LED indicator Switching output Current limit (internal)	Red LED, static ON 24 V DC, active high 200 mA
Battery operation (Battery Mode)	
LED indicator Switching output Current limit (internal) Signal options <sup>1</sup>	Yellow LED, static ON 24 V DC, active high 200 mA BatMode, BatMode Delayed
Battery charging (Battery Charge)	
LED indicator Switching output Current limit (internal) Signal ontions <sup>1</sup>	Yellow LED, flashing 24 V DC, active high 200 mA Bat -Charge Bat -Mode Bat -Mode Delayed, battery almost flat

<sup>&</sup>lt;sup>1</sup> Can be adjusted via UPS-CONF software

# 4.4 Ambient conditions

Climatic requirements		
Ambient temperature		
Operation (> 55°C derating) Storage/transport	-25°C +70°C -40°C +80°C	
Humidity at +25°C, no condensation	95%	
Pollution degree according to EN 50178	2	
Climatic class	3K3	

Mechanical requirements		
Vibration (operation)	< 15 Hz, amplitude ±2.5 mm according to IEC 60068-2-6 15 Hz 150 Hz, 2.3g, 90 min.	
Shock according to IEC 60068-2-27	30g in each direction	

General data	
Insulation voltage I/O (type/routine test)	4 kV AC/2 kV AC
Input/PE (type/routine test)	2 kV AC/2 kV AC
Output/PE (routine test)	500 V DC
Mounting position according to	EN 60715
Degree of protection	IP20
Protection class (with PE connection)	
MTBF according to IEC 61709 (SN 29500)	> 500,000 h
Material	Aluminum (AIMg3)/zinc-plated sheet steel
Dimensions (W/H/D)	60 mm x 130 mm x 118 mm
Weight	1.1 kg

# 4.5 Standards/approvals

Standards/approvals	
Electrical equipment of machines (surge voltage category III)	EN 60204
Safety transformers for switched-mode power supply units	IEC 61558-2-17
Electrical safety (of information technology equipment)	EN 60950/VDE 0805 UL/C-UL Recognized UL 60950 • <b>91</b> us
Industrial control equipment	UL/C-UL Listed UL 508 olums
Electronic equipment for use in power installations	EN 50178 (VDE 0160)
PELV/SELV	PELV (EN 60204)/SELV (IEC 60950)
Safe isolation	VDE 0100-410
Protection against electric shock	DIN 57100-410
Protection against electric shock, basic requirements for safe isolation in electrical equipment	DIN VDE 0106-101
Limitation of mains harmonic currents	EN 61000-3-2

# Conformance with EMC Directive 2004/108/EC, noise immunity according to 2006/95/EC (electromagnetic compatibility)

(electromagnetic compatibility)			
Noise immunity according to EN 61000-6-2			
Electrostatic discharge according to EN 61000-4-2	Housing	Level 3	
	Contact discharge	6 kV	
	Air discharge	8 kV	
	Remark	Criterion B	
Electromagnetic HF field according to EN 61000-4-3	Housing	Level 3	
	Frequency range	80 MHz 2 GHz	
	Field strength	10 V/m	
	Remark	Criterion A	
Fast transients (burst) according to EN 61000-4-4	Input	4 kV (Level 4 - asymmetrical: Cable to ground)	
	Output	2 kV (Level 4 - asymmetrical: Cable to ground)	
	Signal	1 kV (Level 4 - asymmetrical: Cable to ground)	
	Remark	Criterion B	
Surge current loads (surge) according to EN 61000-4-5	Input	4 kV (Level 4 - asymmetrical: Cable to ground)	
		2 kV (Level 4 - asymmetrical: Cable to cable)	
	Output	2 kV (Level 3 - asymmetrical)	
		1 kV (Level 3 - symmetrical)	
	Signal	2 kV (Level 3 - asymmetrical)	
	Remark	Criterion B	
Conducted interference according to EN 61000-4-6	Input/output/signal	Level 3	
	Frequency range	10 kHz 80 MHz	
	Voltage	10 kV	
	Remark	Criterion A	
Noise emission according to EN 61000-6-3	Radio interference voltage according to EN 55011	EN 55011 (EN 55022) Class B, industrial and residential applications	

# 5 Safety regulations

#### Installation notes



#### NOTE:

- The device must only be installed, operated, and maintained by qualified personnel.
- Follow the installation instructions.
- When installing and operating the device, the applicable safety directives (including national safety directives), accident prevention regulations, as well as general technical regulations, must be observed.
- For the safety data, please refer to the package slip and certificates (conformity assessment, other approvals, if necessary).
- Do not repair the device yourself, replace it with an equivalent device.
- Repairs may only be carried out by the manufacturer. The manufacturer is not liable for damage resulting from violation.
- The IP20 degree of protection (IEC 60529/ EN 60529) of the device is intended for use in a clean and dry environment.
- The device must not be subject to mechanical strain and/or thermal loads, which exceed the limits described.

#### **Connection notes**



## **NOTE: Electrostatic discharge**

The device contains components that can be damaged or destroyed by electrostatic discharge. When handling the device, observe the necessary safety precautions against electrostatic discharge (ESD) according to EN 61340-5-1 and EN 61340-5-2.

# 6 Connection, operating, and indication elements




Figure 1 TRIO-UPS/1AC/24DC/5 structure

No.	Description
1	100 240 V AC input
2	24 V rechargeable battery module connection
3	24 V DC output, buffered
4	22.5 29.5 V DC potentiometer
5	Active switching output: Alarm
6	Active switching output: BatMode
7	Active switching output: BatCharge
8	Red LED indicator: Alarm
9	Yellow LED indicator: BatMode/BatCharge
10	Green LED indicator: Power in OK/Overload
11)	Remote shutdown (R1, R2)
12	Buffer time setting
	0.5 20 minutes, PC mode, unlimited ∞
13	ConfigPort
14)	"Confirm" button

### 6.1 Connection terminal blocks

Use a screwdriver with the correct blade width for wiring. For reliable and safe-to-touch connections, strip 8 mm off the cable ends.

The following cable cross-sections can be connected:

Terminal block	Rigid	Stranded	AWG	Tightening torque	
No.	[mm²]	[mm²]		[Nm]	[lb in]
1 - 3,	0.2 - 2.5	0.2 - 2.5	24 - 12	0.5 - 0.6	3.5 - 4.5
<b>(5) - (7),</b>					
11)					



In order to comply with UL approval, use copper cables that are designed for operating temperatures >75°C.

# 6.2 Block diagram




Figure 2 Block diagram for the TRIO-UPS/1AC/24DC/5

#### 6.3 Input

The 100 ... 240 V AC connection is made using the L (+) and N (-) screw connections.

Device installation must be carried out according to the regulations of EN 60950. It must be possible to switch off the device using a suitable disconnecting device outside the power supply.



For example, primary side line protection could be used.

An internal fuse is provided for device protection. Additional device protection is not required.




If an internal fuse is blown, this is due to a device fault. In this case, send the device to Phoenix Contact for inspection.

#### **Network type**

The device can be connected to single-phase AC networks or to two of the phase conductors of three-phase systems (TN, TT or IT networks according to VDE 0100-300/IEC 60364-3) with nominal voltages of 100 V AC ... 240 V AC.



For operation using two phase conductors of a three-phase system, an all-pole disconnecting device must be provided.






Figure 3 Single-phase network systems

# 6.4 Output

The 24 V DC connection is made using the "OUT DC 24 V, +, -" screw connections. The output voltage set upon delivery is 24 V DC. The output voltage can be set from 22.5 V DC to 29.5 V DC on the potentiometer.




Figure 4 Connection

No.	Description		
1	100 240 V AC input		
3	24 V DC output, buffered		
4	22.5 29.5 V DC potentiometer		

## 6.5 LED indicators




Figure 5 LED indicators

No.	Description
8	Red LED indicator: Alarm
9	Yellow LED indicator: BatMode/BatCharge
10	Green LED indicator: Power in OK/Overload

The signal outputs are connected via the "Alarm", "Bat.-Mode", and "Bat.-Charge" terminal blocks. There are three LED status indicators and three active switching outputs for function monitoring.

Status	Green	Yellow	Red	Description
1	0	0	0	The UPS is switched off or the UPS is operating in mains mode, battery mode is deactivated (remote), battery management is still active
2	*	*	*	The UPS is starting mains operation, for the LED test all LEDs are switched on and off again once before the current operating state is indicated
3	*	0	0	The UPS is operating in mains mode, the battery is OK and charged
4	*	*	0	The UPS is operating in mains mode, the battery is OK and is charging (charge < 85% of nominal capacity)
5	0	*	0	The UPS is operating in battery mode, the battery voltage U <sub>BAT</sub> is > 20.4 V
6	0	☆	*	The UPS is operating in battery mode, the battery is almost flat (battery voltage U <sub>BAT</sub> is < 20.4 V)
7	0	0	*	UPS protection against total discharge has terminated battery mode (battery voltage U <sub>BAT</sub> = 19.2 V) and continues indication for a maximum of 10 hours
8	桊	0	*	The UPS is operating in mains mode, the battery is faulty
9	*	0	0	The UPS has been overloaded in mains mode, the battery is OK and charged
10	*	0	*	The UPS has been overloaded in mains mode, the battery is faulty

## Key

LED OFF ○
LED ON ☆
LED flashing

# 7 Installation

A minimum spacing between other devices does not have to be observed in order to ensure correct device function.

# 7.1 Narrow mounting position

The power supply unit can be snapped onto all DIN rails according to EN 60715 and must be mounted horizontally (connection terminal blocks facing upwards and downwards).

# Mounting

Position the module with the DIN rail guideway on the top edge of the DIN rail and then snap it downwards.




Figure 6 Mounting the TRIO-UPS/1AC/24DC/5

#### Removal

Release the snap-on catch using a screwdriver and then detach the module from the bottom edge of the DIN rail.




Figure 7 Removing the TRIO-UPS/1AC/24DC/5

### 7.2 Flat mounting position

A flat mounting position can be achieved by mounting the module onto the DIN rail at a 90° angle. Mount the DIN rail adapter (UTA 107) as shown in the figure. The screws that were previously used to secure the UTA must be used: Torx T10 (0.8 Nm ... 0.9 Nm tightening torque).




Figure 8 Modification for flat mounting position

# 8 Rechargeable battery module

The rechargeable battery module is connected to the power supply unit via the "Battery +" and "Battery -" terminal blocks (2).



#### NOTE: Risk of short circuit

The fuse for the rechargeable battery module must be removed when installing or replacing the module.

The following rechargeable battery modules are recommended:

	Rechargeable battery module	Fuse	Recom- mended charging current
0	MINI-BAT/24DC/1.3Ah	15 A	0.8 A <sup>2</sup>
2	QUINT-BAT/24DC/3.4Ah <sup>1</sup>	25 A	1.0 A <sup>2</sup>
3	QUINT-BAT/24DC/7.2Ah <sup>1</sup>	2 x 25 A	1.5 A <sup>2</sup>
4	QUINT-BAT/24DC/12Ah <sup>1</sup>	2 x 25 A	1.5 A <sup>2</sup>

<sup>&</sup>lt;sup>1</sup> Connection via plug connector, 14 mm

<sup>&</sup>lt;sup>2</sup> Can be adjusted via UPS-CONF software




Figure 9 Characteristic curves for the rechargeable battery modules

Battery mode can be exited after a predefined time has elapsed or by means of external shutdown. If the device is to be shut down after a specific time has elapsed, the time can be set via the selector switch ② on the front of the device. When the supply voltage is reapplied, the device can switch to battery mode again.



The batteries are sealed, maintenance-free lead AGM batteries, which are intended for operating temperatures of 0°C ... 40°C.

They have a service life of six to nine years at an ambient temperature of 20°C.

In order to ensure immediate availability, all batteries are supplied fully charged. Startup should be carried out at the latest after nine months at  $20^{\circ}\text{C}$  ...  $30^{\circ}\text{C}$ , or after six months at  $30^{\circ}\text{C}$  ...  $40^{\circ}\text{C}$ .

# 9 Method of operation

#### 9.1 Output voltage

In mains operation (AC input voltage present) the output voltage of the TRIO-UPS corresponds to the setting at the potentiometer 4. In the event of supply voltage failure, battery mode is activated without interruption. The output voltage is now directly dependent on the battery voltage and is  $U_{BAT}$  -  $0.5\ V.$ 

#### 9.2 Remote shutdown

If the connected load cannot be supplied from the power storage device in the event that the AC voltage fails, the UPS can be disabled via R1/R2. This shutdown can be performed during mains operation or while battery mode is active.

UPS active, remote shutdown deactivated, default upon delivery:

- Terminal points "R1" and "R2" are short circuited (with plug-in bridges by default upon delivery) OR 24 V DC is present at terminal point "R2".
- If the supply voltage fails, the TRIO-UPS switches to battery mode. UPS not active, remote shutdown activated:
- Terminal points "R1" and "R2" are not short circuited AND 0 V DC is present at terminal point "R2".
- All LEDs are OFF.
- If the supply voltage fails, the TRIO-UPS does not switch to battery mode, the device shuts down.
- The connected loads are supplied and the rechargeable battery module is charged as long as the supply voltage is present.

#### 9.3 Buffer time setting

The time after which battery mode is exited is set via the ② selector switch on the front of the device:

- 0.5 to 20 minutes
- Parameterizable time via software ("CUSTOM" switch position, default: 0.5 minutes)
- Unlimited (buffering with the total stored energy)
- PC mode (see Section 9.4 "PC mode")

#### 9.4 PC mode

In "PC mode", the UPS function follows a chronological sequence that can be parameterized via the software and individually optimized for the relevant IPC solution.

Requirements: IFS-USB-PROG-ADAPTER data cable (Order No. 2811271) and UPS-CONF software (Order No. 2320403).

To set the parameters, an Interface interface (IFS) is used for data exchange between the TRIO-UPS and a suitable user interface on the IPC. The user is supported by help texts and graphics for the individual parameters.

As an option, parameterization can be carried out using an IFS-CONFSTICK. Here, a parameter record is transferred from the TRIO-UPS to the IFS-CONFSTICK. This parameter record can then be written to any other TRIO-UPS.

In "PC mode", the UPS function follows a parameterizable chronological sequence of delay time, IPC shutdown, and IPC idle time.

#### Delay time:

If the mains voltage is not applied again within the first 60 seconds of battery mode, for example, "Bat.-Mode" is indicated in order to shut down an IPC with a delay.

#### IPC shutdown:

Shutdown is performed via a data cable to the IPC. The IPC must be connected to the UPS via a USB data cable.

The IPC is supplied by the TRIO-UPS for a parameterizable period of time, e.g., 2 minutes.

### 9.5 PC idle time

Once the "PC shutdown" time has elapsed, the output voltage is switched off, e.g., for 30 seconds (also when the mains voltage is applied again).




Figure 10 Time diagrams

#### 9.6 Battery management

Battery management of the TRIO-UPS is divided into two checks that are performed cyclically during normal operation.

#### **Battery presence check**

The battery presence check is used to detect a correctly installed battery. If this is not the case, the check is failed and the green @ and red ® LED indicators are controlled statically.

# **Battery quality check**

The battery quality check is a lifecycle test. It enables conclusions to be drawn, e.g., regarding the maximum lifecycle of the battery if the maximum charging time has been exceeded. In this case, the green 10 and red 8 LED indicators are controlled statically.

#### 10 Interfaces

#### 10.1 Config.-Port

The TRIO-UPS is connected to the USB connection on the service PC via the "Config.-Port" using the IFS-USB-PROG-ADAPTER data cable.

#### 10.2 IFS-USB-PROG-ADAPTER

The programming adapter (Order No. 2811271) represents the interface between the service PC and the TRIO-UPS and is required in order to parameterize the TRIO-UPS.




Figure 11 Programming adapter

#### 10.3 IFS-CONFSTICK

The IFS-CONFSTICK is a multi-functional memory block for easy storage and back up of configuration and parameter data.

#### Transferring parameters to the IFS-CONFSTICK

To transfer parameters, proceed as follows:

- 1. Press and hold down the "Confirm" button.
- You now have four seconds to carefully insert the IFS-CONFSTICK in the "Config.-Port" on the TRIO-UPS, taking care to observe the connection direction.
- Parameter transfer is started and indicated by the cyclic control of the three LED indicators. Sequence: Red -Yellow - Green
  - a) Error-free transfer: Green LED indicator ON
  - b) Transfer error: Red LED indicator ON

#### Transferring parameters to the TRIO-UPS

To transfer parameters, proceed as follows:

- Carefully insert the IFS-CONFSTICK in the "Config.-Port" on the TRIO-UPS, taking care to observe the connection direction.
- Press and hold down the "Confirm" button for at least six seconds.
- Parameter transfer is started and indicated by the cyclic control of the three LED indicators. Sequence: Green -Yellow - Red
  - a) Error-free transfer: Green LED indicator ON
  - b) Transfer error:Red LED indicator ON

## The following can be parameterized:

- Times
- Switching outputs
- Battery management

# 11 UPS-CONF configuration and management software

The Windows-based UPS-CONF configuration and management software (Order No. 2320403) is used to parameterize the TRIO-UPS.



The UPS-CONF configuration and management software can be downloaded free of charge at www.phoenixcontact.net/download.

Various dialog boxes are available for parameterization. The current operating status of the TRIO-UPS is always displayed at the bottom of the dialog box.



Figure 12 Example, TRIO-UPS status display

A distinction is made between the following states:

Status	Meaning
Operation mode	Preset operating mode at the selector switch ②
Power Source	Power source that is currently active
Battery Condition	Current battery charging state
Device Status	Current state of the TRIO-UPS
Connection to UPS	Connection status between service PC and TRIO-UPS



If an alarm is detected or an existing online connection between the IPC and TRIO-UPS is interrupted, the UPS-CONF dialog box is automatically displayed on screen.

The status is queried cyclically.